

SCHEDULE

APPLICATION NO: 30BL207354

<u>Works</u>	<u>Portion or Lot/Section/DP</u>	<u>Parish</u>	<u>County</u>
1 x Excavation - Ground	155//1186283	Woombah	Clarence

Purpose
Water Supply for Road Making Purposes

Details of Land to be Irrigated

<u>Portion or Lot/Section/DP</u>	<u>Parish</u>	<u>County</u>
----------------------------------	---------------	---------------

Area: Hectares

NSW Office of Water
CONDITIONS STATEMENT
30BL207354

- (1) THE LICENSEE SHALL NOT ALLOW ANY TAILWATER/DRAINAGE TO DISCHARGE INTO OR ONTO:-
- ANY ADJOINING PUBLIC OR CROWN ROAD;
 - ANY OTHER PERSONS LAND;
 - ANY CROWN LAND;
 - ANY RIVER, CREEK OR WATERCOURSE;
 - ANY NATIVE VEGETATION AS DESCRIBED UNDER THE NATIVE VEGETATION CONSERVATION ACT 1997;
 - ANY WETLANDS OF ENVIRONMENTAL SIGNIFICANCE.
- (2) WORKS USED FOR THE PURPOSE OF CONVEYING, DISTRIBUTING OR STORING WATER TAKEN BY MEANS OF THE LICENSED WORK SHALL NOT BE CONSTRUCTED OR INSTALLED SO AS TO OBSTRUCT THE REASONABLE PASSAGE OF FLOOD WATERS FLOWING INTO OR FROM A RIVER.
- (3) DURING THE FIRST YEAR OF ISSUE OF THIS LICENSE THE VOLUMETRIC ALLOCATION IS DIRECTLY PROPORTIONAL FROM THE DATE OF ISSUE OF THE LICENSE TO THE END OF THE IRRIGATION YEAR.
- (4) NSW OFFICE OF WATER SHALL HAVE THE RIGHT DURING THE CURRENCY OF THIS LICENSE TO VARY AT ANY TIME THE VOLUMETRIC ALLOCATION, OR THE RATE AT WHICH THIS ALLOCATION IS TAKEN.
- (5) THE LICENSEE SHALL INSTALL TO THE SATISFACTION OF NSW OFFICE OF WATER IN RESPECT OF LOCATION, TYPE AND CONSTRUCTION AN APPLIANCE(S) TO MEASURE THE QUANTITY OF WATER EXTRACTED FROM THE WORKS. THE APPLIANCE(S) TO CONSIST OF EITHER A MEASURING WEIR OR WEIRS WITH AUTOMATIC RECORDER, OR METER OR METERS OF THE DETHRIDGE TYPE, OR SUCH OTHER CLASS OF METER OR MEANS OF MEASUREMENT AS MAY BE APPROVED BY NSW OFFICE OF WATER. THE APPLIANCE(S) SHALL BE MAINTAINED IN GOOD WORKING ORDER AND CONDITION. A RECORD OF ALL WATER EXTRACTED FROM THE WORKS SHALL BE KEPT AND SUPPLIED TO THE DEPARTMENT UPON REQUEST. THE LICENSEE WHEN REQUESTED MUST SUPPLY A TEST CERTIFICATE AS TO THE ACCURACY OF THE APPLIANCE(S) FURNISHED EITHER BY THE MANUFACTURER OR BY SOME PERSON DULY QUALIFIED.
- (6) THE VOLUME OF GROUNDWATER EXTRACTED FROM THE WORKS AUTHORISED BY THIS LICENCE SHALL NOT EXCEED 20 MEGALITRES IN ANY 12 MONTH PERIOD COMMENCING 1ST JULY.
- (7) THE LICENSEE SHALL CEASE ALL EXTRACTION FROM THE LICENSED WORK AND ADVISE NSW OFFICE OF WATER WHEN THE PH LEVEL OF THE WATER IN THE EXCAVATION IS MEASURED AT 5 OR LESS

End Of Conditions